

CERTIFICATE OF COMPLIANCE

Certificate Number E249019
Report Reference E249019-20070208
Issue Date 2019-DECEMBER-11

Issued to: ELECTRO-SENSORS INC
6111 Blue Circle Dr, Minnetonka MN 55343-9108

This certificate confirms that representative samples of **TELEMETERING EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS**

Vibration Monitor Sensor VS1 and VS2 for use in Class I, Groups C and D; Class II, Groups E, F, and G Hazardous Locations.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations
CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class II, Groups E, F, and G Hazardous Locations
CAN/CSA C22.2 No. 30-M1986, Explosion-Proof Enclosures for Use in Class I Hazardous Locations
UL 508 Part I & CAN/CSA C22.2 No. 14-13 Sections 4 and 5, Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

