

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160222-E249019  
**Report Reference** E249019-20070206  
**Issue Date** 2016-FEBRUARY-22

**Issued to:** ELECTRO-SENSORS INC  
6111 Blue Circle Dr  
Minnetonka MN 55343-9108

**This is to certify that  
representative samples of**

TELEMETERING EQUIPMENT FOR USE IN HAZARDOUS  
LOCATIONS

Device Speed Sensor DN-XP for use in Class I, Groups C  
and D; Class II, Groups E, F, and G Hazardous Locations.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical  
Equipment for Use in Hazardous (Classified) Locations.  
CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class  
II, Groups E, F, and G Hazardous Locations.  
CAN/CSA C22.2 No. 30-M1986, Explosion-Proof  
Enclosures for Use in Class I Hazardous Locations.  
Part I of Standard No. UL 508, Industrial Control  
Equipment.  
Sections 4 and 5 of Standard No. CAN/CSA C22.2 No. 14-  
13, Industrial Control Equipment.

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

